



ADDENDUM NO. 2

Project:

Sump Pump Removal & Replacement at the Third Avenue Parking Garage

For:

Public Parking Authority of Pittsburgh
232 Boulevard of the Allies
Pittsburgh, PA 15222-1616

Date:

August 6, 2018

The previously issued information, in conjunction with the items listed below, are included as part of the Solicitation for Sump Pump Removal and Replacement at the Third Avenue Parking Garage document issued on July 18, 2018, for the above referenced contract.

Item No. 1:

Submitted RFI'S comments and clarifications:

Q.1.) Existing electrical components appear to be rated for hazardous location. Please confirm that newly installed items will be rated NEMA 3R, as discussed at pre-bid.

A.1.) All new electrical material component installation shall be rated NEMA 3R.

(End of Addendum)