

City of Pittsburgh, DPW Review

Reviewed By:

Date:

All sheets must be signed and stamped by a PA licensed Civil Engineer.

Architectural plans for improvements in the Right-of-Way will not be accepted.

Miscellaneous

o Right-of-Way improvement plans must be separate from private improvements.

o Curb cuts must be dimensioned for the entire width of the curb cut. The throat of the driveway is not the curb cut width; maximum allowable curb cut is 36', per City Code, Section 416.01.

Declaration of Responsible Charge:

I hereby declare that I am the Engineer of Work for this project, that I have exercised responsible charge over the design of the project, and that the design is consistent with current standards.

I understand that the check of project drawings and specifications by the City of Pittsburgh is confined to a review only and does not relieve me, as Engineer of Work, of my responsibilities for project design.

Signature

Date

---