



Ed Gainey
Mayor

Sarah Kinter
Director

| <u>System</u> | <u>Requirement</u> | <u>Code Section</u> |
|------------------------------------|---|---------------------|
| Sprinkler System Inspection Record | Annual Record/Visual Inspection | 2018 IFC 901.6.3 |
| Sprinkler Inlet/Room | Visual Inspection | 2018 IFC 903.5 |
| Fire Pump | Annual Record/Visual Inspection | 2018 IFC 913.5 |
| Fire Alarm Panel | Visual Inspection | 2018 IFC 901.6 |
| Fire Alarm Inspection Record | Annual Record/Visual Inspection | 2018 IFC 901.6.3 |
| Emergency Lighting | Annual Record/Visual Inspection | 2018 IFC 1203.5 |
| Generator | Annual Record/Visual Inspection | 2018 IFC 1203.5 |
| Cooking Exhaust Hood | Bi-Annual Record of Cleaning/Visual Inspection | 2018 IFC 607.3 |
| Ansul System | Bi-Annual Record/ Visual Inspection | 2018 IFC 904.12.5 |
| Fire Extinguishers | Annual Record/ Visual Inspection | 2018 IFC 901.6 |
| Fire Hose | 3 year Record/ Visual Inspection | 2018 IFC 901.6 |
| Standpipe | 5 Year Inspection Record/ Visual Inspection | 2018 IFC 901.6 |
| Boiler | License for maintenance | § 745.07 |
| Special Fire Suppression** | Annual Inspection Record/ Visual Inspection | 2018 IFC 901.6 |
| Fire Escape | 5 Year Engineer's Inspection Record/Visual Inspection | 2003 IFC 1026.16.5 |
| Address | Must be posted on business front | 2003 IFC 505.1 |
| Exit Lights | Visual Inspection | 2018 IFC 1031.4 |